





ANNUAL EXIT DOOR LOCKS INSPECTION/TEST REPORT

ELECTRICALLY OPERATED DOOR LOCK SYSTEMS

RETURN COMPLETED FORM TO:

SIGNATURE:

MIAMI BEACH FIRE PREVENTION DIVISION 1701 MERIDIAN AVE.- SUITE 200 MIAMI BEACH, FL 33139 TELEPHONE: 305-673-7123

FAX: 305-673-1085

DATE

ATTENTION INSPECTOR:		
All electrically operated door locks and associated components located at the following address have been inspected and/or tested by the building maintenance engineer for proper operation as required by the adopted codes/standards. All electrically operated door lock systems must be visually inspected at least monthly and functionally tested annually. (NFPA 101 & NFPA 80) The annual testing of the doors concluded that the lock systems are:		
Please circle one:	OPERATIONAL	NOT OPERATIONAL (*)
NAME OF BUILDING:		
ADDRESS OF BUILDING:		
TYPE OF OCCUPANCY (SPECIFIC USE)		
NAME OF OWNER OR AGENT:		
OWNER OR AGENT TELEPHONE :		
PERSON PERFORMING TEST:		
JOB TITLE:		
(*) LIST DEFICIENCIES AND REQUIRED CORRECTIONS:		
having jurisdiction. Lock		all be kept by the owner for inspection by the authority tronically and and will unlock during a power failure or